

General Environmental Incident Summary

Incident: 3750 **Date/Time Notice:** 5/11/2015 1655 **DEM Incident No:**

Responsible Party: Pilot Thomas Logistics

Date Incident: 5/11/2015 **Time Incident:** 1350 **Duration:**

County: Williams **Twp:** 154 **Rng:** 101 **Sec:** 23 **Qtr:** NW SW

Lat: 48.14524 **Long:** -103.64560 **Method:** Address matching

Location Description: Maxum Bulk Plant - Williston
1623 2nd Street West
Williston, ND 58801

Submitted By: David Kilburn

Affiliation:

Address: 2369 S Trenton Way

Suite P

City: Denver

State: CO

Zip: 80231

Received By:

Contact Person: Mike Chapman
5508 Lonas Road
Knoxville, TN 37909

Distance Nearest Occupied Building:

Release Contained: Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Dyed diesel

Volume Spilled: 130.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: No

Reported to NRC: No

Cause of Incident:

Overflow during transport to transport transfer

Risk Evaluation:

None

of Fatalities: 0

of Injuries: 0

Affected Medium: 03 - soil

Potential Environmental Impacts:

Contact with soil

Action Taken or Planned:

Spill was immediately contained using on site absorbent materials. Additional clean up activities are ongoing

Wastes Disposal Location:

Agencies Involved:

Updates

Date: 5/13/2015 **Status:** Reviewed - Follow-up Required

Author: Crowdus, Kory

Updated Volume:

Notes:

Overflow during transport to transport transfer on facility site. Followup is required.

Date: 5/14/2015 **Status:** Inspection

Author: Martin, Russell

Updated Volume:

Notes:

5/14/2015 at 11:10, on location. According to personnel at site, spill was not at Maxum facility, but Thomas Fuels facility nearby. Went to facility; arrived at 11:20 and met with site personnel. According to site personnel, spill occurred due to human error. Spill occurred along east side of facility and collected in parking area. Impacted area has been scraped up and placed in a rolloff on site. Work is still in progress, and spots of staining are still visible on facility ground. No off-site impact visible.

Date: 2/24/2016 **Status:** Inspection

Author: Martin, Russell

Updated Volume:

Notes:

2/24/2016 at 15:30, on location. Met with site personnel. Area cleaned up; no staining remains. No further follow-up required.